

Report No.: PKS190411002-10

Test Time: 2019-4-17 10:31

Luminaire Property

Luminaire Manufacturer:

Luminaire Category:

Luminaire Description: DS73V2XX

Lamp Description:

Lumens per Lamp:

Luminous Width (mm):

Voltage: 120.0 V

Power: 21.24 W

Lamp Catalog:

Number of Lamps:

Luminous Length (mm):

Luminous Height (mm):

Current: 0.178 A

Power Factor: 0.992

Photometric Results

CIE Class: General Diffuse

Measurement Flux: 1687.5 lm

Downward Ratio: 52%

Field Angle(C0/C180,C90/C270,C45/C225,C135/315): 360.0, 357.0, 360.0, 360.0

Beam Angle(C0/C180,C90/C270,C45/C225,C135/315): 360.0, 177.3, 181.2, 168.1

Luminaire Efficacy Rating (LER): 79.50

Max. Intensity: 349.7 cd

S/MH(C0/C180): 1.26

Total Rated Lamp Lumens: 1687.5 lm

Efficiency: 100%


Upward Ratio: 48%

C0r0 Intensity: 136.1 cd


Pos of Max. Intensity: H90 V70

S/MH(C90/C270): 2.12

Picture Of Luminaire



Luminous Intensity Distribution Curve



Unit: cd

Average Diffuse Angle(50%): 268.7°

— C0-C180 — C90-C270

C Plane (°):0.0-360.0: 22.5

Test Lab: Bacl

Test Type: TYPE C

Temperature: 24.6 °C

Operator: KOBE

Gamma Plane (°):0.0-180.0:5.0



Test Device: GPM-3000

Distance: 14.073 m

Humidity: 48

Inspector:


Luminous Intensity Distribution Curve



C Plane (°):0.0-360.0: 22.5
Test Lab: Bacl
Test Type: TYPE C
Temperature: 24.6 'C
Operator: KOBE

Gamma Plane (°):0.0-180.0:5.0
Test Device: GPM-3000
Distance: 14.073 m
Humidity: 48
Inspector:

Luminous Intensity Distribution Curve(cd/klm)




Coefficients Of Utilization - Zonal Cavity Method

RC	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.5	0.5	0.5	0.3	0.3	0.3	0.1	0.1	0.1	0
RW	0.7	0.5	0.3	0.1	0.7	0.5	0.3	0.1	0.5	0.3	0.1	0.5	0.3	0.1	0.5	0.3	0.1	0
RCR	RF = 0.2																	
0	1.08	1.08	1.08	1.08	1.00	1.00	1.00	1.00	.85	.85	.85	.71	.71	.71	.58	.58	.58	.52
1	.94	.88	.83	.78	.87	.81	.77	.72	.68	.65	.61	.56	.54	.51	.45	.43	.41	.36
2	.84	.75	.67	.60	.77	.69	.62	.56	.58	.52	.48	.47	.43	.40	.38	.34	.32	.27
3	.76	.64	.56	.49	.69	.59	.51	.45	.49	.43	.38	.40	.36	.32	.32	.28	.25	.21
4	.69	.56	.47	.40	.63	.52	.43	.37	.43	.37	.31	.35	.30	.26	.28	.24	.21	.17
5	.63	.50	.40	.33	.57	.46	.37	.31	.38	.31	.26	.31	.26	.22	.25	.21	.17	.14
6	.58	.44	.35	.28	.53	.41	.32	.26	.34	.27	.22	.28	.23	.19	.22	.18	.15	.12
7	.53	.39	.31	.24	.48	.36	.28	.23	.30	.24	.19	.25	.20	.16	.20	.16	.13	.10
8	.49	.36	.27	.21	.45	.33	.25	.20	.28	.21	.17	.23	.18	.14	.18	.14	.11	.09
9	.46	.32	.24	.19	.42	.30	.22	.17	.25	.19	.15	.21	.16	.12	.17	.13	.10	.08
10	.42	.29	.22	.16	.39	.27	.20	.15	.23	.17	.13	.19	.14	.11	.15	.12	.09	.07

Spacing Criteria (0-180): 1.26

Spacing Criteria (90-270): 2.12


Spacing Criteria (Diagonal): 1.91



C Plane (°):0.0-360.0: 22.5
Test Lab: Bacl
Test Type: TYPE C
Temperature: 24.6 'C
Operator: KOBE

Gamma Plane (°):0.0-180.0:5.0
Test Device: GPM-3000
Distance: 14.073 m
Humidity: 48
Inspector:

IsoLux Plot



Mounting Height: 10.0m Max Lux(100%): 1.9 lx

(1%): 0.0 lx	(2%): 0.0 lx
(5%): 0.1 lx	(10%): 0.2 lx
(20%): 0.4 lx	(50%): 0.9 lx



C Plane (°):0.0-360.0: 22.5
Test Lab: Bacl
Test Type: TYPE C
Temperature: 24.6 'C
Operator: KOBE

Gamma Plane (°):0.0-180.0:5.0
Test Device: GPM-3000
Distance: 14.073 m
Humidity: 48
Inspector:

Lum Limit Curve

Dazzle	Quality	Illuminance (lx)							
1.15	A	2000	1000	500	<=300				
1.50	B		2000	1000	500	<=300			
1.85	C			2000	1000	500	<=300		
2.20	D				2000	1000	500	<=300	
2.55	E					2000	1000	500	<=300

a b c d e f g h




L(cd/sq.m)	G45	G50	G55	G60	G65	G70	G75	G80	G85
C0	84	74	63	52	43	34	25	16	7
C90	315	327	337	344	348	350	349	345	339
C180	99	90	81	71	60	50	40	29	19
C270	103	96	90	86	81	80	83	83	78


C Plane (°):0.0-360.0: 22.5
Test Lab: Bacl
Test Type: TYPE C
Temperature: 24.6 'C
Operator: KOBE

Gamma Plane (°):0.0-180.0:5.0
Test Device: GPM-3000
Distance: 14.073 m
Humidity: 48
Inspector:

Illuminance at a Distance



Vertical IsoLux Plot




Lowest(m): 1.0m Highest(m): 11.0m Max Lux: 136.1 lx
 (1%): 1.4 lx (2%): 2.7 lx
 (5%): 6.8 lx (10%): 13.6 lx
 (20%): 27.2 lx (50%): 68.1 lx

C Plane (°):0.0-360.0: 22.5
 Test Lab: Bacl
 Test Type: TYPE C
 Temperature: 24.6 'C
 Operator: KOBE

Gamma Plane (°):0.0-180.0:5.0
 Test Device: GPM-3000
 Distance: 14.073 m
 Humidity: 48
 Inspector:

The Average Illuminance Effective Figure



UGR Table

Reflectance:										
Ceiling (cavity)	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions	Viewed crosswise					Viewed endwise				
X=2H Y=2H	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$
3H	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$
4H	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$
6H	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$
8H	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$
12H	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$
X=4H Y=2H	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$
3H	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$
4H	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$
6H	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$
8H	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$
12H	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$
X=8H Y=4H	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$
6H	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$
8H	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$
12H	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$
X=12H Y=4H	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$
6H	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$
8H	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$
Variations with the observer position at spacings:										
S=1.0H	-1.\$/-1.\$					-1.\$/-1.\$				
S=1.5H	-1.\$/-1.\$					-1.\$/-1.\$				
S=2.0H	-1.\$/-1.\$					-1.\$/-1.\$				

Calculate in accordance with CIE Pub.117. The table is revised with 1688lm ($8\log(F/F_0) = 1.8$).

C Plane (°):0.0-360.0: 22.5
Test Lab: Bacl
Test Type: TYPE C
Temperature: 24.6 'C
Operator: KOBE

Gamma Plane (°):0.0-180.0:5.0
Test Device: GPM-3000
Distance: 14.073 m
Humidity: 48
Inspector:

Utilisation Factor Table(Floor cavity)

Utilisation Factors UF(F)			SHR NOM = 2.00									
Room Reflectance			Room Index(RI)									
Ceiling	Wall	Floor	0.75	1.00	1.25	1.50	2.00	2.50	3.00	4.00	5.00	
0.70	0.50	0.20	NA	0.49	0.54	0.59	0.66	0.71	0.74	0.79	0.82	
	0.30		NA	0.41	0.47	0.51	0.59	0.64	0.68	0.74	0.78	
	0.20		NA	0.35	0.40	0.45	0.53	0.59	0.63	0.69	0.74	
0.50	0.50	0.20	NA	0.41	0.46	0.50	0.56	0.60	0.63	0.67	0.69	
	0.30		NA	0.35	0.40	0.44	0.50	0.55	0.58	0.63	0.66	
	0.20		NA	0.31	0.35	0.39	0.46	0.50	0.54	0.59	0.63	
0.30	0.50	0.20	NA	0.34	0.38	0.41	0.46	0.49	0.52	0.55	0.57	
	0.30		NA	0.30	0.33	0.37	0.42	0.46	0.48	0.52	0.55	
	0.20		NA	0.26	0.29	0.33	0.38	0.42	0.45	0.49	0.52	
0.00	0.00	0.00	NA	0.18	0.20	0.23	0.27	0.30	0.32	0.35	0.37	
Rating:21W Photometrically tested without ceiling board. Multiply UF values by service correction factors Calculate in accordance with CIBSE Technical Memorandum NO.5 1980												

Utilisation Factor Table(Wall)

Utilisation Factors UF(W)			SHR NOM = 2.00									
Room Reflectance			Room Index(RI)									
Ceiling	Wall	Floor	0.75	1.00	1.25	1.50	2.00	2.50	3.00	4.00	5.00	
0.70	0.50	0.20	NA	0.84	0.74	0.66	0.55	0.47	0.41	0.33	0.28	
	0.30		NA	0.72	0.65	0.59	0.49	0.43	0.38	0.31	0.27	
	0.20		NA	0.62	0.57	0.53	0.45	0.40	0.36	0.30	0.25	
0.50	0.50	0.20	NA	0.72	0.64	0.58	0.48	0.42	0.36	0.29	0.25	
	0.30		NA	0.63	0.57	0.52	0.43	0.38	0.34	0.28	0.24	
	0.20		NA	0.55	0.51	0.47	0.40	0.35	0.32	0.26	0.23	
0.30	0.50	0.20	NA	0.62	0.55	0.49	0.41	0.35	0.31	0.26	0.22	
	0.30		NA	0.54	0.49	0.45	0.38	0.33	0.30	0.24	0.21	
	0.20		NA	0.48	0.45	0.41	0.35	0.31	0.28	0.23	0.20	
0.00	0.00	0.00	0.52	0.34	0.32	0.30	0.26	0.23	0.21	0.17	0.15	
Rating:21W Photometrically tested without ceiling board. Multiply UF values by service correction factors Calculate in accordance with CIBSE Technical Memorandum NO.5 1980												

Utilisation Factor Table(Ceiling cavity)

Utilisation Factors UF(C)			SHR NOM = 2.00									
Room Reflectance			Room Index(RI)									
Ceiling	Wall	Floor	0.75	1.00	1.25	1.50	2.00	2.50	3.00	4.00	5.00	
0.70	0.50	0.20	NA	0.64	0.65	0.65	0.66	0.66	0.67	0.67	0.67	
	0.30		NA	0.57	0.58	0.59	0.60	0.61	0.62	0.63	0.64	
	0.20		NA	0.52	0.53	0.54	0.56	0.57	0.58	0.60	0.61	
0.50	0.50	0.20	NA	0.61	0.62	0.63	0.63	0.64	0.64	0.64	0.64	
	0.30		NA	0.56	0.57	0.58	0.59	0.59	0.60	0.61	0.61	
	0.20		NA	0.52	0.53	0.53	0.55	0.56	0.57	0.58	0.59	
0.30	0.50	0.20	NA	0.59	0.60	0.60	0.61	0.61	0.61	0.62	0.62	
	0.30		NA	0.55	0.56	0.56	0.57	0.58	0.58	0.59	0.59	
	0.20		NA	0.51	0.52	0.52	0.54	0.55	0.55	0.56	0.57	
0.00	0.00	0.00	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	
Rating:21W Photometrically tested without ceiling board. Multiply UF values by service correction factors Calculate in accordance with CIBSE Technical Memorandum NO.5 1980												

Zonal Lumen

Gamma [°]	I _{mean} [cd]	Zonal Flux [lm]	Sum Zonal Flux [lm]	Rel Zonal Flux [%]	Sum Rel Zonal Flux [%]
0.0-5.0	136.2	3.3	3.3	0.19	0.19
5.0-10.0	132.6	9.5	12.7	0.56	0.76
10.0-15.0	123.4	14.6	27.4	0.87	1.62
15.0-20.0	123.2	20.3	47.7	1.20	2.83
20.0-25.0	135.6	28.4	76.1	1.69	4.51
25.0-30.0	145.8	36.9	113.0	2.19	6.70
30.0-35.0	150.0	44.2	157.2	2.62	9.32
35.0-40.0	152.8	51.0	208.2	3.02	12.34
40.0-45.0	154.7	57.3	265.5	3.39	15.73
45.0-50.0	154.7	62.5	328.0	3.70	19.43
50.0-55.0	152.9	66.5	394.5	3.94	23.37
55.0-60.0	149.8	69.3	463.7	4.10	27.48
60.0-65.0	145.9	70.9	534.6	4.20	31.68
65.0-70.0	141.6	71.7	606.4	4.25	35.93
70.0-75.0	137.4	71.8	678.2	4.26	40.19
75.0-80.0	132.9	71.1	749.3	4.22	44.40
80.0-85.0	127.2	69.1	818.4	4.10	48.50
85.0-90.0	121.9	66.8	885.2	3.96	52.46
90.0-95.0	119.4	65.4	950.6	3.87	56.33
95.0-100.0	117.2	63.7	1014.2	3.77	60.10
100.0-105.0	117.0	62.6	1076.9	3.71	63.81
105.0-110.0	122.1	63.8	1140.7	3.78	67.60
110.0-115.0	128.7	65.2	1205.9	3.86	71.46
115.0-120.0	134.0	65.2	1271.0	3.86	75.32
120.0-125.0	138.2	63.9	1334.9	3.79	79.11
125.0-130.0	141.1	61.4	1396.3	3.64	82.74
130.0-135.0	142.4	57.6	1453.9	3.41	86.15
135.0-140.0	142.3	52.7	1506.6	3.12	89.28
140.0-145.0	140.5	46.9	1553.5	2.78	92.06
145.0-150.0	136.9	40.3	1593.8	2.39	94.45
150.0-155.0	130.7	33.1	1626.9	1.96	96.41
155.0-160.0	118.6	24.9	1651.7	1.47	97.88
160.0-165.0	102.1	16.8	1668.6	1.00	98.88
165.0-170.0	91.6	10.9	1679.4	0.64	99.52
170.0-175.0	86.3	6.2	1685.6	0.37	99.89
175.0-180.0	80.5	1.9	1687.5	0.11	100.00

C Plane (°):0.0-360.0: 22.5
 Test Lab: Bacl
 Test Type: TYPE C
 Temperature: 24.6 'C
 Operator: KOBE

Gamma Plane (°):0.0-180.0:5.0
 Test Device: GPM-3000
 Distance: 14.073 m
 Humidity: 48
 Inspector:

Candlepower Table

Unit: cd

G\C	C0.0	C22.5	C45.0	C67.5	C90.0	C112.5	C135.0	C157.5	C180.0	C202.5
G0.0	136.1	136.1	136.1	136.1	136.1	136.1	136.1	136.1	136.1	136.1
G5.0	134.9	138.3	145.3	150.5	153.2	152.2	147.9	141.5	135.8	132.5
G10.0	132.6	142.6	159.6	171.3	177.5	174.8	165.4	150.4	134.6	126.7
G15.0	128.9	146.6	172.9	191.9	201.0	196.9	182.3	158.4	132.5	117.2
G20.0	124.2	149.9	185.6	211.3	224.0	218.5	197.5	165.4	129.4	103.1
G25.0	118.3	151.8	196.6	229.4	245.7	238.3	212.2	171.0	125.2	81.2
G30.0	111.3	152.4	206.3	245.8	265.8	257.1	224.8	175.3	119.9	54.5
G35.0	103.0	151.8	214.5	261.1	284.3	273.7	236.0	178.1	113.9	30.9
G40.0	94.1	149.9	221.2	274.3	300.9	288.9	245.4	179.5	106.7	28.0
G45.0	84.5	146.8	226.2	285.7	315.3	301.9	253.4	179.6	98.8	37.4
G50.0	73.9	142.7	229.5	294.6	327.4	312.7	259.1	178.3	90.2	49.7
G55.0	63.1	137.2	230.9	301.5	337.2	320.8	262.7	175.6	80.6	48.1
G60.0	52.4	131.1	230.8	305.9	344.0	326.7	264.7	171.5	70.7	41.2
G65.0	42.7	123.9	228.3	307.8	348.1	329.9	264.1	166.1	60.5	34.9
G70.0	33.6	115.7	224.4	307.9	349.7	330.5	261.7	159.3	50.1	29.4
G75.0	24.5	107.2	218.9	305.4	348.7	328.8	257.3	151.9	39.5	22.8
G80.0	15.7	98.0	212.2	300.6	345.0	324.3	251.5	143.6	29.1	18.4
G85.0	7.2	88.9	204.2	293.7	338.8	318.2	244.0	134.9	19.3	14.8
G90.0	1.2	82.6	199.0	290.0	335.6	314.6	239.8	129.6	14.3	9.4
G95.0	5.6	88.3	205.4	296.0	341.4	320.9	246.2	135.8	21.4	3.8
G100.0	12.9	96.8	212.7	301.9	346.6	326.5	252.9	143.8	30.3	10.3
G105.0	20.9	104.9	218.3	305.5	348.9	329.4	257.7	150.8	39.6	16.8
G110.0	29.3	112.3	223.1	306.8	349.0	330.0	260.7	157.1	48.9	23.1
G115.0	37.9	119.0	225.8	306.3	345.8	328.1	261.6	162.1	58.2	29.4
G120.0	46.4	125.1	226.6	302.9	340.6	323.2	260.5	165.9	67.2	35.4
G125.0	55.6	130.2	226.0	297.2	332.4	316.0	257.2	168.4	75.8	41.9
G130.0	63.9	134.3	223.2	289.2	321.6	306.4	252.0	169.6	83.9	42.2
G135.0	71.4	137.3	218.8	279.2	308.5	294.4	244.9	169.4	91.1	31.0
G140.0	76.7	139.5	212.6	266.5	293.0	279.9	235.6	168.0	96.9	24.1
G145.0	77.5	140.2	205.1	252.1	275.2	263.2	224.9	165.2	101.2	28.8
G150.0	76.3	140.1	195.6	236.1	255.2	245.3	212.3	160.8	102.2	45.8
G155.0	74.0	138.0	185.3	218.3	234.2	225.2	198.3	152.8	100.9	58.5
G160.0	70.5	133.3	173.8	199.3	211.6	203.7	181.6	134.5	98.1	64.1
G165.0	66.4	125.9	160.8	179.4	189.1	181.9	157.9	111.4	94.4	66.5
G170.0	64.5	108.8	143.4	157.9	164.4	156.9	116.8	89.1	87.5	65.6
G175.0	82.5	91.2	99.6	125.2	132.5	106.3	84.6	89.9	85.3	79.7
G180.0	93.3	94.6	93.8	81.6	26.0	61.5	83.9	89.3	93.2	94.6

C Plane (°):0.0-360.0: 22.5
 Test Lab: Bacl
 Test Type: TYPE C
 Temperature: 24.6 'C
 Operator: KOBE

Gamma Plane (°):0.0-180.0:5.0
 Test Device: GPM-3000
 Distance: 14.073 m
 Humidity: 48
 Inspector:

Candlepower Table (Continue 1)

Unit: cd

G\C	C225.0	C247.5	C270.0	C292.5	C315.0	C337.5	C360.0			
G0.0	136.1	136.1	136.1	136.1	136.1	136.1	136.1			
G5.0	128.1	122.3	120.4	121.0	125.9	131.1	134.9			
G10.0	106.8	75.0	60.2	67.0	96.3	121.1	132.6			
G15.0	59.0	15.3	25.1	20.1	36.5	102.6	128.9			
G20.0	14.9	59.9	96.1	78.5	26.5	68.9	124.2			
G25.0	39.8	119.0	124.0	122.1	79.0	31.0	118.3			
G30.0	86.9	113.0	118.2	116.2	111.5	20.9	111.3			
G35.0	96.2	107.0	114.2	111.2	104.5	41.4	103.0			
G40.0	89.0	102.6	109.9	107.3	97.9	72.2	94.1			
G45.0	82.3	96.2	102.9	100.2	92.7	77.4	84.5			
G50.0	77.2	88.7	95.9	92.9	85.2	69.5	73.9			
G55.0	69.3	81.6	90.5	86.9	77.0	62.1	63.1			
G60.0	61.2	75.7	85.9	81.5	69.4	56.0	52.4			
G65.0	54.6	70.5	81.3	76.3	63.4	48.0	42.7			
G70.0	49.4	67.4	79.7	73.4	57.7	40.6	33.6			
G75.0	46.1	66.9	82.6	73.6	54.5	36.7	24.5			
G80.0	43.0	66.1	82.7	72.4	51.6	34.0	15.7			
G85.0	37.1	61.2	77.5	68.6	46.1	27.2	7.2			
G90.0	33.1	58.8	76.4	67.3	43.8	24.8	1.2			
G95.0	25.3	46.7	64.3	55.3	34.7	8.8	5.6			
G100.0	6.7	20.1	38.2	28.5	11.6	9.5	12.9			
G105.0	16.8	15.8	21.7	16.8	13.6	18.6	20.9			
G110.0	26.9	29.1	32.6	28.7	26.1	27.0	29.3			
G115.0	36.1	40.1	44.5	40.7	36.6	34.9	37.9			
G120.0	44.7	50.0	53.8	50.7	46.3	42.9	46.4			
G125.0	52.8	58.8	63.0	59.9	55.4	50.5	55.6			
G130.0	60.8	67.2	70.9	68.4	64.2	57.7	63.9			
G135.0	68.5	75.1	78.8	76.3	72.4	64.8	71.4			
G140.0	74.9	82.8	86.4	83.8	80.3	71.0	76.7			
G145.0	81.0	90.0	93.6	91.0	87.0	48.9	77.5			
G150.0	75.4	95.8	100.0	97.1	93.4	25.2	76.3			
G155.0	31.9	101.3	105.6	102.9	83.4	14.7	74.0			
G160.0	11.0	53.0	91.5	77.8	30.1	34.4	70.5			
G165.0	34.7	12.7	24.8	20.8	18.0	52.6	66.4			
G170.0	56.8	38.1	31.0	38.1	56.3	57.3	64.5			
G175.0	72.1	53.4	44.3	65.4	51.1	65.4	82.5			
G180.0	93.8	81.7	25.4	61.3	83.9	89.3	93.3			

C Plane (°):0.0-360.0: 22.5
Test Lab: Bacl
Test Type: TYPE C
Temperature: 24.6 'C
Operator: KOBE

Gamma Plane (°):0.0-180.0:5.0
Test Device: GPM-3000
Distance: 14.073 m
Humidity: 48
Inspector: